

ADDENDUM NO. 3

DATE

June 17, 2024

PROJECT

KNIGHTS LANDING RIDGE DRAINAGE DISTRICT – RIDGE CUT
EROSION REPAIR PROJECT PHASE 1B

NOTICE TO PROSPECTIVE BIDDERS

THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL BIDDING DOCUMENTS DATED MAY 2024, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM AND SIGNATURE LINE BELOW. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

BIDDER'S ADDENDUM 3 RECEIPT SIGNATURE: _____

ADDITIONAL SUPPLEMENTAL PROJECT FILES INCLUDE:

- BIDDING RFI'S AND QUESTIONS RESPONSES – DATED JUNE 17, 2024

-- END OF ADDENDUM NO. 3 --

KLRDD Ridge Cut Phase 1B
Questions and Answers
June 17th, 2024
Addendum 3 Supplemental Project File

No.	Question	Answer
14	Who is responsible for trimming / clearing trees for access to place rock?	The contractor must trim trees as needed for the project's execution and handle the resulting materials by either stockpiling or off-hauling them. Special care must be taken regarding permits, particularly concerning the allowable extent of trimming and removal. The contractor is permitted to off-haul materials but may only stockpile woody vegetation in the designated staging area.
15	What is the contractor expected to do with downed trees in the construction zone?	Downed trees in the waterway shall remain in the waterway. Trees laying on the slope to be armored shall be removed as the contractor's property.
16	Is the contractor responsible for removing vegetation on site and off-hauling?	The contractor must remove vegetation as needed for the project's execution and handle the resulting materials by either stockpiling or off-hauling them. Special care must be taken regarding permits, particularly concerning the allowable extent of grubbing and root removal. The contractor is permitted to off-haul materials but may only stockpile woody vegetation in the designated staging area.
17	Will the contractor be responsible to obtaining the SWPPP plan from a qualified firm?	No. The District is to provide the SWPPP.